

FALCON ASSOCIATES

HEAD OFFICE:

216, Durais complex 1st floor
Rajamull Road
Opp to C.I Lodge
Pollachi - 642001
Ph: 04259- 228257

BRANCH OFFICE:

986/11, Kamala Krishna Towers,
2nd Floor - Kamarajar Road, Lakshmiaram,
Ramanuja Nagar Bus Stop,
Perlamodu - Coimbatore - 641015
Phone No: 0422- 2573259.

Email: falconpoy2003@gmail.com Cell: 98431 - 28257 Web: www.falconmk.com

STABILITY CERTIFICATE

Name of the School:

" NOYYAL PUBLIC SCHOOL "

Address:

S.F.No.26/A2,26/B2 & 23/B2,
No.10, Muthur Village,
Kinathukadavu Taluk,
Coimbatore District.

Purpose:

School Purpose

Dr.M.V.Mohanakrishnan, Ph.D., MRICS (LONDON), ✦

B.E. (Civil & Mech), M.Sc. (Struct. Engg), M.S. (REVISED), MBA, M.L.L.
F.I.C. (F.I.C.), F.A.C.I. (M.C. & P.), D.Eng. S and Val. (C.D. in Struct. Engg.)
F. Regd. (F. Regd.) & F.I.E. Principal Consultant

Chartered Surveyor, Chartered Engineer
Govt. Approved Valuer, Professional Engineer and
Arbitrator

✦ Structural Consultant, Civil & Mechanical Engineer

✦ Regd. Valuer for Income Tax, Wealth Tax &
Gift Tax.

✦ Collector's Panel Engineer - Class - 1A
for Coimbatore, Tirupur & The Nilgiris Districts
Tamil Nadu Public Building (Licensing) Act
1965, Govt. of Tamil Nadu.

✦ Approved competent Person Office of the
Industrial Safety and Health, Tamil Nadu.

✦ Panel Valuer for Banks -
Immovable properties, plant & machineries.



ENGINEERS & VALUERS

J. d. k.
NOYYAL PUBLIC SCHOOL (GUSE)
No. 10, Muthur, Kinathukadavu
Coimbatore (Dt) - 642 106.

G. S. S.
Correspondent
NOYYAL PUBLIC SCHOOL
No. 10, Muthur, Kinathukadavu - 642 106
Coimbatore (Dt)

FORM A

(Form of application under sub-section (1) Sub-section (2) of section 4 of the Madras Public Buildings (Licensing) Act, 1965(Madras Act. 13 of 1965) referred to in Rule 3 of the Madras Public Buildings (Licensing) Rules 1966)

From

The Correspondent,
NOYYAI PUBLIC SCHOOL
S.F.No.26/A2,26/B2 & 23/B2,
No.10, Muthur Village,
Kinathukadavu Taluk,
Coimbatore District.

To

The Tahsildar,
Kinathukadavu.

Sir,

1. I Intend / to use the building / to continue to use the existing building not at present used as public building / which is situated in S.F.No.26/A2,26/B2 & 23/B2, No.10, Muthur Village, Kinathukadavu Taluk, Coimbatore District and specified in the statement enclosed, as a public building for a period of Three years and months from the 10.08.2020 to 09.08.2023

2. The year of construction and present approximate ease of construction and the purpose for which it is to be used or is being used as public building as also furnished in the statement accompany this application.


3. I enclose a chalan for Rs. _____


4. I also enclose a certificate of structural soundness in the prescribed form furnished by the District Collector's Panel Engineer **Dr. M.V.MOHANAKRISHNAN**, Ph.D, MRICS, [London] B.E. (Civil), B.Tech (Mech), M.E. Strut (Hons), M.Sc(REV) (P&M) - M.B.A., M.I.E., F.I.V. F.I.C.C., F.A.C.C.E., M.I.C.A., P.G.D in QS and Valn, P.G.D in Strut (Hons), C.Engg. P.Engg & L.I.B
Coimbatore District Collector's Panel Engineer Registration No.02 / 2016 Class-1A

Date

Enclosure:

1. Statement
2. Chalan for Rs. _____ towards the application fee.


NOYYAI PUBLIC SCHOOL (CORP)
No. 10, Muthur, Kinathukadavu
Coimbatore (Dt) - 642 109.


Correspondent
Noyyal Public School
No. 10 Muthur Kinathukadavu - 642 109
Coimbatore (Dt)

M.V. MOHANAKRISHNAN Ph.D., MRICS (LONDON),
 B.Sc. (Tech), M.E. (Struct./Hvac), M.Sc. (SEI), M.Sc. (PAM), M.S.A., M.I.E., F.I.C.E.,
 F.I.E., M.I.C.A., P.O. in DS (Hb), P.O. in Struct./Hvac, C.Engg., F.Engg., M.I.E.R.
PRINCIPAL CONSULTANT

- Chartered Surveyor, Chartered Engineer
- Govt. Approved Valuer, Professional Engineer & Arbitrator
- Structural Consultant, Civil & Mechanical Engineer
- Regd. Valuer for Income Tax, Wealth Tax & Gift Tax
- Collector's Panel Engineer - CLASS 1A, for Coimbatore, Tirupur & The Nilgiris Districts, Tamil Nadu, Public Building Act - 1965
- Competent Person - Industrial Safety and Health, Tamil Nadu
- Panel Valuer for Banks, immovable Properties, Plant & Machines



Falcon Associates Engineers & Valuers

An ISO 9001:2015 Certified Engg. Concern



Kamalakrishna Towers,
 386/11, 2nd Floor, Kamarajar Road,
 Lakshmiapuram, Ramanujam Nagar Bus Stop,
 Peelamedu, Coimbatore - 641 004
 Ph: 0422 2573259, 0422 43781221
 Cell: 98431 28257, 94437 28257
 E-mail: falconpoy2003@gmail.com

No 10172

POY2007022

DECLARATION

I **M.V.Mohanakrishnan** office at Falcon Associates, Kamalakrishna Towers, 386/11, 2nd Floor, Kamarajar Road, Lakshmiapuram, Ramanujam Nagar Bus Stop, Peelamedu, Coimbatore - 641 015. Do hereby declare that I possess the qualification and experience specified in the Table to rule 11 of the Madras Public Building (Licensing) Rules 1966 for issuing the certificate of Structural Soundness of the Building covered by the certificate.

Station : Coimbatore

Date : 23.07.2020



M. V. Mohan
23.07.2020

Signature of the certifying Engineer
 Registration No: 02/2016, Class : 1A

Dr. M.V. MOHANAKRISHNAN Ph.D., MRICS (London),
 B.Sc. (Tech), M.E. (Struct./Hvac), M.Sc. (SEI), M.Sc. (PAM), M.S.A., M.I.E., F.I.C.E.,
 F.I.E., M.I.C.A., P.O. in DS (Hb), P.O. in Struct./Hvac, C.Engg., F.Engg., M.I.E.R.
 Regd. No. 02/2016, Class - Class 1A

FALCON ASSOCIATES
 COIMBATORE DISTRICT
 COLLECTOR'S PANEL ENGINEER
 PWD APPROVED ENGINEER
 GOVERNMENT OF TAMILNADU
 CELL : 98431 28257

V. J. Jeyaraj
Principal

ROYAL PUBLIC SCHOOL (CBSE)
 No. 10, Muthur, Kinnathukadavu,
 Coimbatore (Dt) - 642 108

Chandrasekhar

Correspondent
Royal Public School
 No. 10 Muthur, Kinnathukadavu - 642 108
 Coimbatore (Dt)

1. Name and Address of the Collectors
Panel Engineer

Dr. M.V Mohanakrishnan,
Kamalakrishna Towers, 386/11,
2nd Floor, Kamarajar Road, Lakshmiapuram,
Ramanujam Nagar Bus Stop
Peelamedu, Coimbatore - 641 015
Phone : 0422 - 2573259.

2. Engineering Qualification

..... Ph.D., MRICS [London] B.E. (Civil), B.Tech (Mech),
M.E. Strut (Hons), M.Sc(REV), M.B.A., M.I.E., F.I.V.,
F.L.C.C., F.A.C.C.E., M.I.C.A., P.G.D in QS and Valn,
P.G.D in Strut (Hons), C.Engg., P.Engg. & L.L.B

3. P.W.D Panel Engineer Appd. No

..... Board of Eng. Proceeding No:
AEE/T1/AE/21807/2016
P.W.D - Chepauk - Chennai,
Govt. of Tamil Nadu.

4. Collector Panel Engineer
Appd. No

CLASS - 1A

..... Coimbatore District's - Panel of Registered
Engineer Ref : 22934/2015/ C2,
Dated on : 15.07.2016

5. Number of years of experience
and nature thereof

..... A total of 26 Years experience in
Construction field (Designing and
Execution of Multistoried framed
Structures including 5 years
Service in Foreign Countries)



Memo
23.07.2020

Dr. M.V. MOHANAKRISHNAN Ph.D., MRICS (London)
B.L.C.C., F.I.V., F.I.C.C., F.A.C.C.E., M.I.C.A., P.G.D in QS and Valn, M.S.C (REV), M.B.A., M.I.E., F.I.V.,
F.L.C.C., F.A.C.C.E., M.I.C.A., P.G.D in QS and Valn, P.G.D in Strut (Hons), L.L.B.
Regd. No : 622016, Class : Class 1A

FALCON ASSOCIATES
COIMBATORE DISTRICT
COLLECTOR'S PANEL ENGINEER
PWD APPROVED ENGINEER
GOVERNMENT OF TAMILNADU
CELL : 98431 28257



[Handwritten signature]

NOYYAL PUBLIC SCHOOL (CBSE)
No. 10, Methur, Kinathukadavu
Coimbatore (Dt) - 642 109.

[Handwritten signature]
Correspondent

Noyyal Public School
No. 10 Methur Kinathukadavu - 642 109
Coimbatore (Dt).

STATEMENT ACCOMPANYING FORM A

1. Name of the School : "NOYYAL PUBLIC SCHOOL"
2. Location (Street No/ Ward No. Name of place i.e. Corporation/Municipality/ Panchayat Union / Township / Cantonment) : SF No.26/A1,26/B2 & 23/B2, No.10, Marthur Village, Kinathukadavu Taluk, Coimbatore District.
3. Year of construction : 2011
4. Approximate Cost of Construction as per Current rates : Rs. 240.00 Lakhs
5. Purpose for which the building is being used or proposed to be used : School Purpose.
6. Purpose for which the Building has Hitherto Been Used : School Purpose.
7. Details of construction of the building particulars of foundation soil, specification of the various parts under

Framed Structure Building

- a) Foundation : P.C.C. 1:4:8 Mix for foundation-Concrete Random rubble masonry in cm 1:5 mix wall footing. Isolated footing for columns.
- b) Basement : Brick basement over plinth beams.
- c) Super structure : Brick Masonry with CM & Plastered with CM and finished with one coat of White cement and color washcoat
- d) Floor and roof : Cement concrete flooring and R.C.C. Roof Slab.



[Signature]
25.07.2020

Dr. M.V. MOHAMMADSHAHAN
Collector, Coimbatore District
No. 10, Marthur Village, Kinathukadavu Taluk, Coimbatore District.

FALCON ASSOCIATES

COIMBATORE DISTRICT
COLLECTOR'S OFFICE
P.O. APPROVED ENGINEER
OFFICE NO. 10, MARATHUR VILLAGE,
KINATHUKADAVU TALUK, COIMBATORE DISTRICT.



[Signature]
Correspondent

Mayur Public School
No. 10 Marthur Village, Coimbatore (Dt)

[Signature]
NOYYAL PUBLIC SCHOOL (P.S.)
No. 10, Marthur Village, Kinathukadavu Taluk,
Coimbatore (Dt)

FORM NO. B

(FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB SECTION (G) OF SECTION 4 OF THE TAMIL NADU PUBLIC BUILDINGS (LICENSING) ACT 1965 (TAMILNADU ACT 13 OF 1965) REFERRED TO IN RULE 4 OF THE TAMILNADU PUBLIC BUILDINGS (LICENSING) RULES 1966)

I certify that I have inspected the building mentioned in the statement and furnished below its salient features.

1. FOUNDATION

(i) Depth below ground level	:	2.44 M for Foundation depth
(ii) Nature of soil met with at	:	Hard gravelly soil
(iii) Probable safe bearing capacity Of the soil met with at foundation	:	33.00 Kg / CM ²
(iv) Pressure at foundation	:	15.00Kg / CM ²

2. SUPER STRUCTURE

(i) Maximum stress in the most Critical section of masonry and concrete	:	R.C.C 1 : 2 : 4 50.00 Kg / Cm ² B.W in C.M 12.50 M.T / Sft.
(ii) Nature of masonry and concrete and its safe permissible stress	:	R.C.C 1 : 2 : 4 100.00 Kg / Cm ² B.W in C.M 35.00 M.T / Sft.

The structural soundness of the building has been verified by me with reference to I.S.I. Loading standards 875 (Latest version) and other relevant Indian standard code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A license may be granted for the period from 10.08.2020 To 09.08.2023

M. V. Mohan
23.07.2020

Date: 23.07.2020.



SIGNATURE OF THE ENGINEER
Address:

Dr. M.V. MOHANAKRISHNAN P.E. (R.C.C) Member
E.L.C.E.I. Inst. Party. Member. Member M.S. (Civil) M.B.A.
MILITARY ENGINEER (Retd) Govt. Serv. (Retd) (1981-86)
Regd. No. 022010. Class. Class 1A

FALCON ASSOCIATES
COIMBATORE DISTRICT
COLLECTOR'S PANEL ENGINEER
PWD APPROVED ENGINEER
GOVERNMENT OF TAMIL NADU
CELL : 99421122

(Signature)

Correspondent
Nayyal Public School
No. 16, Main Road, Kumbhataduru - 642 109
Coimbatore (Dt)

(Signature)
NOYAL PUBLIC SCHOOL (P.B.S.)
No. 16, Main Road, Kumbhataduru
Coimbatore (Dt) - 642 109.



e) Door and Windows	Steel Doors & Windows.
f) No. of storeys.	Ground Floor only
8. Period for which license required	3 years from <u>10.08.2020 To 09.08.2023</u>
9. No. of. Persons to be accommodated	550 Nos.

BUILD-UP AREA DETAILS:-

AREA OF THE EXLG.F R.C.C.ROOF A BLOCK BUILDING	= 6500.00SFT
AREA OF THE EXLG.F R.C.C.ROOF B BLOCK BUILDING	= 9000.00SFT
AREA OF THE EXLG.F R.C.C.ROOF C BLOCK BUILDING	= 6000.00SFT
AREA OF THE EXLG.F R.C.C.ROOF D BLOCK BUILDING	= 3500.00SFT

SIGNATURE OF THE OWNER
OF THE BUILDING
Date:



SIGNATURE OF THE ENGINEER
Date: 23.07.2020

M. V. Mohan
23.07.2020

Dr. M.V. MOHANAKRISHNAN Ph.D., M.B.E., M.S.E.,
M.E., D.I.T. (Struct. Engg.), M.T.E., M.S., M.S.E., M.B.A.,
M.L.P.V.C.C., P.E.D., P.E., M.S., P.E.C. - Joint Member, I.A.
Regd. No. 02 2011 Class. Other IA



FALCON ASSOCIATES
COIMBATORE DISTRICT
COLLECTOR'S PANEL ENGINEER
PWD APPROVED ENGINEER
GOVERNMENT OF TAMILNADU
CELL : 98431 28257

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh license in case any alteration is made to the existing building or portion of building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the building or a portion of the building originally is changed or altered subsequently.

Date: *[Signature]*
ROYAL PUBLIC SCHOOL (CO-BO)
No. 10, Muthukumar Street,
Coimbatore (TN) - 642 128.
Contact No. 98431 28257

SIGNATURE OF THE OWNER
OF THE BUILDING
[Signature]
Correspondent
Royal Public School
No. 10 Muthukumar Street,
Coimbatore (TN)

**STATEMENT ACCOMPANYING
THE CERTIFICATE OF STRUCTURAL SOUNDNESS**

1. Location of the building, Door Number,
Street and Name of the place : "NOYYAL PUBLIC SCHOOL"
S.F.No 26/A2,26/B2 & 23/B2,
No.10, Muthur Village,
Kinathukadavu Taluk,
Coimbatore District.
2. The Value of the building
at the Current rates : Rs. 240.00 Lakhs
3. Age of the building : 9 Years
4. Number of Storeys : Ground Floor only
5. Short description of structures –
Steel - RCC framed or load
Bearing masonry. : RCC Roof Framed Structure
G.F only – Brick work with Plastered
Steel doors with cement flooring etc..
6. Purpose for which the building is
Certified for use : School Purpose.
7. The period for which the building will be
Structurally sound : 3 Years 10.08.2020 To 09.08.2023
8. Number of persons to be
Accommodated. : 550 Nos.
9. Remarks : Regular Maintenance is required.

Date: 23.07.2020



M. V. Mohanarishnan
23.07.2020
SIGNATURE OF THE ENGINEER
Address:

Dr. M.V. MOHANARISHNAN P.W.D. COLLECTOR'S
OFFICE, 5th Floor, P.W.D. Building, No. 10, Muthur,
Kinathukadavu Taluk, Coimbatore District, K.A.
Regd. No. 23/2019, Dist. Coimbatore

FALCON ASSOCIATES

COIMBATORE DISTRICT
COLLECTOR'S PANEL ENGINEER

P.W.D. APPROVED ENGINEER
GOVERNMENT OF TAMIL NADU

CELL : 08431 28267

[Signature]
NOYYAL PUBLIC SCHOOL,
No. 10, Muthur, Kinathukadavu
Coimbatore (Dt) 641 011

[Signature]

Correspondent

Noyyal Public School

No.10 Muthur, Kinathukadavu - 641 011
Coimbatore (Dt)



FORM C

Form of certificate of Structural Soundness under sub-section (4) of section 4 of the Madras Public Buildings (Licensing) Act 1965 (Madras Act 13 of 1965) referred to in rule 4 of the Madras Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the building mentioned in the statement below and I have satisfied myself that the building is structurally sound to be used as a public building for the purpose noted in the statement. The structural soundness of the building has been verified taking into account the Loading as per the latest Indian standards 875. A license may be granted for three years period from 10.08.2020 To 09.08.2023 (inclusive).

Date: 23.07.2020



M. M. M.
23.07.2020

SIGNATURE OF THE ENGINEER
Address:



Dr. M.V. MOHANAKRISHNAN P.D.JNTUC(London)
BE.(Civil) B.Tech (Mech) M.E.Struct (Hons) M.Sc (Mach) M.B.A.
MIE, R.W.F.C.C. PGD - QS Van PGD in Struct (Hons) I. A.
Regd. No - 02/2016 Class Class 1A

FALCON ASSOCIATES
COIMBATORE DISTRICT
COLLECTOR'S PANEL ENGINEER
PWD APPROVED ENGINEER
GOVERNMENT OF TAMILNADU
CELL : 98431 28267

Gandey
Correspondent

Noyyal Public School
No. 10 Munhur, Kinathukadavu - 676 109
Coimbatore (Dt)

V. J. J.

NOYYAL PUBLIC SCHOOL (CBSE)
No. 10, Munhur, Kinathukadavu
Coimbatore (Dt) - 676 109.

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS.

Door no of the Building (Door No., Street, name of the place)	Age of the building	The Value of the building at the Current rates	Number of Storeys	Short description of structures - Steel - RCC framed or load Bearing masonry	Purpose for which the building is Certified for use	The period for the building will be structurally sound	Number of persons to be Accommodated Nos.	Remarks
1 "NOYYAL PUBLIC SCHOOL" S.F.No.26/A2,26/B2 & 23/B2, No.10, Muthur Village, Kinathukadavu Taluk, Coimbatore District.	2 9 Years	3 Rs.240.00 Lakhs	4 Ground Floor only.	5 Framed Structure Building	6 School Purpose.	7 3 Years. From 10.08.2020 To 09.08.2023	8 550 Nos	9 Regular Maintenance is required

Date: 23.07.2020



SIGNATURE OF THE ENGINEER
 Address:
M. V. Mohan
 23.07.2020



DR. M. V. MOHANAKRISHNAN PWD (Retired)
 BELONG: Bhop. Prachi, Madhya Pradesh, M.S. (Nagpur),
 M.E.J.V.E.C.C. (E.C.C. - 03) War. PWD in Service (P.W.D. ALLA,
 Regd. No: 02/2016, Class: Class 1A
FALCON ASSOCIATES
 COIMBATORE DISTRICT
 COLLECTOR'S PANEL ENGINEER
 PWD APPROVED ENGINEER
 GOVERNMENT OF TAMILNADU
 CELL : 98421 28267

[Handwritten Signature]

NOYYAL PUBLIC SCHOOL (CBSE)
 No.10, Muthur, Kinathukadavu
 Coimbatore (Dt) - 642104

[Handwritten Signature]
 Correspondent

Noyyal Public School
 No.10 Muthur, Kinathukadavu - 642104

FORM - I

Form of Report to be made to the competent Authority by Inspecting Authorities or Officers Under Section 238 of the Madras Public Building(Licensing Act 1965 Madras act 13 of referred to in rule 7 of the Madras Public Building (License) Rule 1966

1. Name and designation of Inspecting authority or Officer appointed of having Justification Under other act of law : **Dr.M.V.Mohanakrishnan.**
2. Location of the Building Inspected (Door No.st. Name of the Place i.e. Municipal Corporation /Municipality Union /Township/Cantonment : **NOYYAL PUBLIC SCHOOL, S.F.No 26/A2,26/B2 & 23/B2, No.10, Muthur Village, Kinathukadavu Taluk, Coimbatore District.**
3. Date of Inspection : **23.07.2020**
4. Purpose for which the Building is used : **School Purpose**
5. Nature of defects Noticed : **Nil**
6. Suggestion for rectifying Defects : **Nil**
7. If in a dangerous condition Immediate steps recommended To be taken : **Regular Maintenance is required**

Conditions for the Existing Structures:

1. This building was inspected on 23.07.2020 along with the Mr.Sankar (Cell: 97875-60906) for structural soundness verification.
2. If any cracks etc., developed in the Structure in the said period for which Stability Certificate issued, should be brought to the notice of the undersigned Panel Engineer.
3. The Structural Soundness Certificate shall be revoked if any defects are notice during the said period.
4. The Panel Engineer reserves the right to inspect the Building at any working hours and if any defects found during his visit then this Structural Soundness Certificate may be revoked without assigning any reasons.
5. No addition or alteration should be made to the existing Structure or portion of the Building without the prior written permission from the Panel Engineer empanelled by the District Collector of the particular District
6. If any alterations or additions made to the existing Building covered in this Structural Soundness Certificates, a fresh Soundness Certificate should be obtained from the Panel Engineer of the particular District under the relevant Class.
7. Any other activities other than School without the Knowledge of the undersigned will not bind this stability certificate.
8. Legal aspects are not considered in this stability certificate.
9. The proper maintenance of the site and building to be given to keep the structural stability in a good manner. Further it is informed that any defects or collapse if any.
10. Due to any removal of any part of the building the undersigned is not responsible for the same. Caused due to Natural Calamities like Earthquake, Cyclones, Floods, Heavy Ram etc., are not considered in the stability of building
11. This certificate being issued only for the stability and Soundness of the building for the duration of period mentioned in this report.
12. Report contains 12 Pages.

Signature of the Owner of the Building

Date

[Handwritten Signature]



SIGNATURE OF THE ENGINEER

Date: 23.07.2020.

[Handwritten Signature]
23.07.2020

Dr. M.V. MOHANAKRISHNAN
 BELONGS TO THE DISTRICT ENGINEER, COIMBATORE
 MIE CIVIL ENGINEER IN CHARGE FOR PG & S
 Regd No. 02/2010, Class C
FALCON ASSOCIATES
 Correspondent
 Noyyal Public School
 No. 10, Muthur, Kinathukadavu - 642 109
 Coimbatore (Dt)

NOYYAL PUBLIC SCHOOL (CUSE)
 No. 10, Muthur, Kinathukadavu
 Coimbatore (Dt) - 642 109

